

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0028:219 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Notifier, One Fire-Lite Place, Northford CT 06472-1653
Contact: Larry Flood (203) 484-1200 Fax (203) 484-7309

DESIGN: Models XP6-R relay module, XP6-C supervising control module, XP10-M input monitor module and *XP6-MA six zone interface module. All devices are intended to be connected between the signaling line circuit of a compatible fire alarm control panel. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-33 VDC Primary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed compatible fire alarm control units.

NOTE: *If an external power supply is used for Model XP6-MA, the negative of the external power supply is referenced to the negative of the auxiliary supply of the compatible control panel. This is done in order to detect ground faults on the initiating circuit.

Rev. 3-07-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager